

**ADDENDUM NO. 3  
CITY OF BELEN, NEW MEXICO  
SEPTEMBER 8, 2017**

**TO: All Plan Holders**

**RE: Belen Fire Station No. 1**

The following Addendum shall be incorporated into the Contract Documents for the above-referenced project.

**I. DRAWINGS**

**A. SHEET E-102:**

1. Modify General Note 1:
  - a. Replace "E-104" with "E-106"

**B. SHEET E-106:**

1. Add General Note #8 to read:

"WIFI Routers (access points) are Owner provided and installed; coordination with Owner's IT Dept required."
2. Add the following to Keyed Note #26:

"Lighting Arrestor shall be PlyPhaser Corporation, or Engineer reviewed equivalent. (Contractor to verify frequency of radio is concurrent to arrester.)"
3. Add Keyed Note #29 (which applies to antenna shown on PA System Connection Diagram) to read:

"Contractor to remove and relocate the existing antenna located at the existing fire station to the new station. See Antenna Mounting Diagram on E-105."
4. Add Keyed Note #30 (which applies to coax cable shown on PA System Connection Diagram) to read:

"Provide nominal 50 Ohm impedance. Andrew LDF4-50A 1/2" Heliax™ Transmission Line, or Engineer reviewed equivalent. Provide grounding kit, Andrew 204989-1, or Engineer reviewed equivalent. (Impedance matching to be confirmed in field with existing antenna.)"

**II. CLARIFICATIONS TO QUESTIONS**

**A. QUESTIONS:**

1. Q: Who is providing the Antenna for the PA System shown on Drawing E-106?  
A: (See above for resolution).
2. Q: I need a make and model for the lightning arrester. The spec on the radio doesn't show what type of connection is being used.  
A: (See above for resolution).
3. Q: What type of coax cable is required for the antenna?  
A: (See above for resolution).
4. Q: Who is providing the wireless routers (access points)?  
A: (See above for resolution).

All other provisions of the Contract Documents shall remain unchanged. This Addendum is hereby made a part of the Contract Documents to the same extent as those contained in the original documents and all itemized listings thereof.

Each Bidder shall acknowledge receipt of this Addendum on the Bid Form in the space provided.

MOLZEN CORBIN

John Quinn Pate, R.A. / R.L.A.