

**ADDENDUM NO. 2  
CITY OF BELEN, NEW MEXICO  
SEPTEMBER 24, 2021**

**TO: All Planholders**

**RE: 2021 COOP Improvements – Sixth Street Reconstruction**

The following Addendum shall be incorporated into the Contract Documents for the above-referenced project.

**A. PROJECT MANUAL**

1. **BID FORM FOR CONSTRUCTION CONTRACT:**
  - a. Remove and replace Pages 1-2 of Bid Form with the revised Pages 1-2 included in this Addendum No. 2. Changes include:
    - 1) The removal of base course material shall be incidental to Item No. 1.
    - 2) The drive pad on the west side of 6th Street near the NM 309 intersection is intended to be removed and replaced. The Keyed Notes have been amended to the re-issued Sheets C-101 and C-202 and Item Nos. 6a. and 16a have been added in the Bid Form. Removal and replacement of the curb directly adjacent to the drive pad shall be incidental to these line items.
    - 3) Item No. 9 has been revised to specify that the oil in the asphalt mix design shall comply with the New Mexico Department of Transportation Standard Specification for SP IV.
    - 4) Item No. 19 "Replace Existing Traffic Sign." has been removed and the Item Nos. following have been renumber accordingly.

**B. DRAWINGS**

1. **SHEET C-101, EXISTING CONDITIONS / DEMOLITION PLAN:**
  - a. Remove and replace Sheet C-101 with the revised Sheet C-101, included in this Addendum No. 2.
2. **SHEET C-202, SIXTH STREET PLAN AND PROFILE STA. 13+00.00 TO STA. 15+31.00:**
  - a. Remove and replace Sheet C-202 with the revised Sheet C-202, included in this Addendum No. 2.

All other provisions of the Contract Documents shall remain unchanged. This Addendum is hereby made part of the Contract Documents to the same extent as those contained in the original documents and all itemized listings thereof.

Each Bidder shall acknowledge receipt of this Addendum No. 2 on the Bid Proposal form in the space provided.

MOLZEN CORBIN

  
Melina L. Boyd, P.E.      9/24/2021  
Date

# BID FORM FOR CONSTRUCTION CONTRACT

PROJECT IDENTIFICATION: 2021 COOP Improvements – Sixth Street Reconstruction

## ARTICLE 1 – BID RECIPIENT

1.01 This Bid is submitted to:

City of Belen

100 South Main Street

Belen, New Mexico 87002

1.02 The undersigned Bidder proposes and agrees, if this Bid is accepted, to enter into an Agreement with Owner in the form included in the Bidding Documents to perform all Work as specified or indicated in the Bidding Documents for the prices and within the times indicated in this Bid and in accordance with the other terms and conditions of the Bidding Documents.

## ARTICLE 2—ATTACHMENTS TO THIS BID

2.01 The following documents are submitted with and made a condition of this Bid:

- A. Required Bid security;
- B. List of Proposed Subcontractors for compliance with New Mexico Subcontractor's Fair Practices Act;
- C. List of Proposed Suppliers;
- D. Evidence of authority to do business in the state of the Project; or a written covenant to obtain such authority within the time for acceptance of Bids;
- E. Contractor's license number as evidence of Bidder's State Contractor's License or a covenant by Bidder to obtain said license within the time for acceptance of Bids;
- F. Required Bidder Qualification Statement with supporting data;
- G. Resident Contractor Certificate issued by the Taxation and Revenue Department (if seeking preference);
- H. Resident Veteran Contractor Certificate issued by the Taxation and Revenue Department (if seeking preference);

## ARTICLE 3—BASIS OF BID—LUMP SUM BID AND UNIT PRICES

3.01 *Unit Price Bids*

A. Bidder will perform the following Work at the indicated unit prices:

Item No.	Description	Unit	Est. Qty.	Bid Unit Price	Bid Price
Demo					
1	Mill Existing Pavement, Stockpile. Includes Incidental Removal of Base Course.	SY	1,836	\$	\$

EJCDC® C-410, Bid Form for Construction Contract.

Copyright© 2018 National Society of Professional Engineers, American Council of Engineering Companies,  
and American Society of Civil Engineers. All rights reserved.

Page 1 of 2

Item No.	Description	Unit	Est. Qty.	Bid Unit Price	Bid Price
2	Sawcut Existing Pavement, Neat Line.	LF	118	\$	\$
3	Remove Existing PCC Valley Gutter.	SY	34	\$	\$
4	Remove Existing PCC Curb and Gutter.	LF	89	\$	\$
5	Remove Existing Storm Drain Inlet.	EA	2	\$	\$
6	Remove Existing Sidewalk.	SY	33	\$	\$
6a	Remove Existing PCC Drivepad and Adjacent PCC Curb.	SY	61	\$	\$
7	Removed Existing SAS Concrete Collar.	EA	1	\$	\$
8	Traffic Sign, Remove, and Reset.	EA	1	\$	\$
<b>Roadway Improvements</b>					
9	3" Asphalt Pavement, SPIV, 2-1.5" Lifts. Oil in the Asphalt Mix Shall Comply with NMDOT SP IV.	SY	1,836	\$	\$
10	6" Aggregate Base Course, 95% Compaction, Complete in Place (CIP).	SY	1,836	\$	\$
11	12" Subgrade Prep, CIP.	SY	1,836	\$	\$
12	Tack Coat, CIP.	SY	1,836	\$	\$
13	Prime Coat, CIP.	SY	1,836	\$	\$
14	Modified Curb and Gutter.	LF	89	\$	\$
15	PCC Valley Gutter, Including fillet.	SY	75	\$	\$
16	ADA Pedestrian Ramps.	EA	3	\$	\$
16a	PCC Drivepad, CIP. Removal and Replacement, Including Incidental Replacement of the Curb Directly Adjacent to the Drive Pad.	SY	61	\$	\$
17	Storm Drain Inlet, Type B.	EA	2	\$	\$
18	Seal Pavement Edge.	LF	118	\$	\$
19	Adjust Existing SAS Manhole to New Grade, Including Concrete Collar.	EA	1	\$	\$
<b>Miscellaneous</b>					
20	Mobilization.	LS	1	\$	\$
21	Traffic Control.	LS	1	\$	\$
22	Pre-Authorized Changes During Construction.	ALLOW	ALLOW	\$ 4,000.00	\$ 4,000.00
23	Utility Relocation Allowance.	ALLOW	ALLOW	\$ 2,500.00	\$ 2,500.00
24	Material Testing Allowance.	ALLOW	ALLOW	\$ 3,000.00	\$ 3,000.00
25	Construction Staking.	LS	1	\$	\$

**TOTAL BID AMOUNT (Exclusive of New Mexico Gross Receipts Tax)**

**\$\_\_\_\_\_**

B. Bidder acknowledges that:

- each Bid Unit Price includes an amount considered by Bidder to be adequate to cover Contractor's overhead and profit for each separately identified item, and
- estimated quantities are not guaranteed, and are solely for the purpose of comparison of Bids, and final payment for all Unit Price Work will be based on actual quantities, determined as provided in the Contract Documents.

EJCDC® C-410, Bid Form for Construction Contract.

Copyright© 2018 National Society of Professional Engineers, American Council of Engineering Companies, and American Society of Civil Engineers. All rights reserved.

Page 2 of 2

NUMERIC SCALE CONFIRMATION  
DRAWINGS ARE DEPICTED AT INTENDED  
NUMERIC SCALES  
IF THIS BAR EQUALS ONE INCH

[illegible]


# EXISTING CONDITIONS / DEMOLITION PLAN

## ADDENDUM NO. 2

CITY OF BELEN - ROAD IMPROVEMENT PROJECT  
SIXTH STREET ROAD IMPROVEMENTS  
BELEN, NEW MEXICO 87002


C-101

SHEET





## KEYED NOTES

- 1 MILL EXISTING ASPHALT PAVEMENT SURFACE
- 2 REMOVE AND REPLACE EXISTING STORM DRAIN INLET
- 3 BEGIN REMOVE AND REPLACE EXISTING CURB AND GUTTER
- 4 END REMOVE AND REPLACE EXISTING CURB AND GUTTER
- 5 REMOVE AND REPLACE EXISTING VALLEY GUTTER
- 6 REMOVE AND REPLACE EXISTING PEDESTRIAN RAMP
- 7 EXISTING SIGN TO REMAIN IN PLACE
- 8 EXISTING SIGN TO BE REMOVED AND RELOCATED
- 9 EXISTING SIGN TO BE REMOVED AND REPLACED
- 10 REMOVE EXISTING CONCRETE COLLAR AROUND SAS MANHOLE
- 11 EXISTING UTILITY TO REMAIN IN PLACE
- 12 SAWCUT NEAT LINE
- 13 EXISTING DRIVEPAD TO REMAIN IN PLACE
- 14 REMOVE AND REPLACE EXISTING DRIVEPAD
- 15 EXISTING STORM DRAIN INLET TO REMAIN IN PLACE




**CAUTION:**  
NOTE THAT ALL EXISTING UTILITIES MAY NOT BE SHOWN. EXISTING SERVICE CONNECTIONS ARE NOT SHOWN. ANY EXISTING UTILITIES THAT ARE SHOWN ARE SHOWN IN APPROXIMATE LOCATION ONLY. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO CONTACT ALL THE UTILITY OWNERS AND TO CONDUCT ALL NECESSARY FIELD INVESTIGATIONS PRIOR TO ANY EXCAVATION TO DETERMINE THE ACTUAL LOCATION OF UTILITIES AND OTHER IMPROVEMENTS.

PLOT DATE: 9/24/2021 11:23 AM  
C:\BELLEN\BLN205-11.DWG  
C:\BELLEN\BLN205-11.DWG



- KEYED NOTES**
- 1 NEW ASPHALT PAVEMENT SECTION PER PAVEMENT SECTION DETAIL SHEET C-501
  - 2 10'-8" DROP INLET FOR TYPE 'B' CURB PER NMDOT STANDARD DETAIL 623-14-1/3
  - 3 EXISTING STORM DRAIN MANHOLE TO REMAIN IN PLACE
  - 4 NOT USED
  - 5 ADJUST EXISTING MANHOLE TO NEW GRADE INCLUDING NEW CONCRETE COLLAR
  - 6 BEGIN NEW CURB AND GUTTER TO MATCH ADJACENT CURB AND GUTTER
  - 7 END NEW CURB AND GUTTER TO MATCH ADJACENT CURB AND GUTTER
  - 8 NOT USED
  - 9 NOT USED
  - 10 END VALLEY GUTTER WITHOUT FILLET
  - 11 BEGIN NEW DRIVEPAD SEE TYPICAL DRIVEPAD SECTION C-501 AND SEE DETAIL 2C SHEET C-505
  - 12 END NEW DRIVEPAD



**MOLZENCORBIN**

2701 Miles Road SE  
Albuquerque, New Mexico 87106  
505 242 5700 office  
505 242 0673 fax  
MolzenCorbin.com

NOTICE OF EXTENDED PAYMENT PROVISION:  
THIS CONTRACT ALLOWS THE OWNER TO MAKE  
PAYMENT WITHIN 45 DAYS AFTER SUBMISSION  
OF AN UNDISPUTED REQUEST FOR PAYMENT

**NUMERIC SCALE CONFIRMATION**  
DRAWINGS ARE DEPICTED AT INTENDED  
NUMERIC SCALES  
IF THIS BAR EQUALS ONE INCH

*Melvin Boyd*  
MELVIN BOYD  
NEW MEXICO  
24510  
PROFESSIONAL ENGINEER  
9/24/2021

REV NO	REV DATE	DESCRIPTION

PROJECT NUMBER:	BLN205-11
DESIGNED BY:	M. BOYD
DRAWN BY:	J. BEHREND
CHECKED BY:	K. EADES
PRIME DESIGN PROFESSIONAL:	MELVIN BOYD
PROJECT DATE:	SEPTEMBER 2021

SIXTH STREET  
PLAN & PROFILE STA. 13+00.00 TO STA. 15+31.00  
ADDENDUM NO. 2

CITY OF BELEN - ROAD IMPROVEMENT PROJECT  
SIXTH STREET ROAD IMPROVEMENTS  
BELEN, NEW MEXICO 87002

**C-202**

SHEET